

BID COMPARISONS

Replacement of the sewage pumping station located at 96 East Moser Road, Thurmont, MD (McDonald's Pump Station). Contractor shall provide all equipment and labor needed to furnish and install the following to Town of Thurmont standards and requirements:

- 1) One 72" diameter precast concrete Wet Well
- 2) One 72" diameter precast concrete top to include one 4" vent pipe, one aluminum hatch door supplied by the Town.
- 3) Supply all pipe and pipe fittings needed to construct a duplex pump system.
- 4) Install Pump bases with check valves; Stainless Steel guide rails and upper mounting brackets; crane and base; new pump electrical panel; stainless steel float rack bracket

Vendor	Bid Amount	Comments
Pumping Solutions, Inc. York Springs, PA.	\$34,790.41	Low Bidder. References checked – all results positive. Has worked with municipalities in PA. Recommended Vendor
Guyer Brothers, Inc. New Enterprise, PA.	\$44,648.00	
W.F. Delauter & Son, Inc. Emmitsburg, MD.	\$46,873.00	
Mid-Atlantic Utilities, Inc. Boiling Springs, PA.	\$59,585.00	